



INSTYTUT NAFTY I GAZU – Państwowy Instytut Badawczy
OIL AND GAS INSTITUTE – National Research Institute
PL 31-503 Kraków, ul. Lubicz 25 A
tel.: +48 12 421 00 33 www.inig.pl office@inig.pl

BIURO CERTYFIKACJI
CERTIFICATION OFFICE
tel.: +48 12 430 38 64 e-mail: swat@inig.pl



AC 010

NATIONAL CERTIFICATE OF THE CONSTANCY OF PERFORMANCE AC010 – UWB – 0005

In compliance with Regulation issued by Minister of Infrastructure and Construction of 17th November 2016 r. on the way of declaring the performance of construction products and method of marking them with the construction products mark (Polish Journal of Laws of 2016 item 1966) this certificate applies to the construction products:

Whiteheart threaded malleable cast iron pipe fittings according to EN-GJMW-400-5 for gas installations in buildings (gaseous fuels according to PN-C-04750:2011)

models: "A" elbows; "B" and "E" tees; "C" crosses; "M" sockets, "N" nipples; "D" and "G" bends; "T" caps and plugs; "Za" side outlet elbows; "U1" end "U2" union elbows; "UA1" end "UA2" union elbows

zinc coating: 500 g/m²; *average thickness of the coating layer:* min 70µm
surface free of polycyclic aromatic hydrocarbons

threads according: PN-EN 10226-1:2006; PN-EN 10226-1:2007
dimension: ¹/₄ ÷ 2 (DN8 ÷ DN50); MOP5; T2 (-20°C ÷ 60°C)

covered by Polish standard for products:

**PN-EN 10242:1999 + A1:2002 + A2:2005
[EN 10242:1994 + A1:1999 + A2:2003]**

placed on the market under the name or trade mark of:

**Odlewnia Zawiercie Spółka Akcyjna
42-400 Zawiercie ul. Leśna 10**

and produced in the manufacturing plant:

**Odlewnia Zawiercie Spółka Akcyjna
42-400 Zawiercie ul. Leśna 10**

This certificate attests that all provisions resulting from national system 1 concerning the AVCP in relation to the declared performance of product connected with its intended use described in hereby certificate are applied and that:

**the manufacturer has implemented the system of factory production control
in order to maintain the constancy of the performance**

This certificate replaces the certificate of conformity No. 29/12 of 11.05.2016 and will remain valid as long as neither the Polish standard used, the AVCP methods, construction product itself nor the manufacturing conditions are modified significantly, unless suspended or withdrawn by the accredited certification body.

Certification Office Manager

Magdalena Swat



Kraków, 07-06-2018

Director of the INIG-PIB

Maria Ciechanowska